

FIRE EXTINGUISHER

MONTHLY INSPECTION CERTIFICATE

PASS

ASSET	10 lb ABC extinguisher
ASSET ID	FEX-3F-12
LOCATION	3rd Floor / East Corridor
INSPECTION DATE	August 30, 2026
INSPECTOR	Sofia Grant

INSPECTION ITEMS

	PASS	Pressure gauge	Needle is within the operable range
	PASS	Hose assembly	No cracks, blockage, or damage
	PASS	Mounting bracket	Secure and accessible
	PASS	Service tag	Tag is present and legible

CERTIFICATION

The listed extinguisher was visually inspected and was accessible, charged, and free from visible damage at the time of inspection.

Sofia Grant

Inspector signature

August 30, 2026

Inspection date